



**Danfoss A/S**

6430 Nordborg  
Denmark  
CVR nr.: 20 16 57 15

Telephone: +45 7488 2222  
Fax: +45 7449 0949

**MANUFACTURER'S DECLARATION**

**Danfoss A/S**  
**Danfoss Cooling Segment**

declares under our sole responsibility that the

**Product category :** Thermal Expansion Valves, Capacity Regulator, Flare/Solder Adaptor, Liquid Distributor

**Type designation(s):**

- Thermal Expansion Valves Type TD1/TDE1
  - Type TE5-TE12-TE20-TE55
  - Type TGE10-TGE20-TGE40
- Capacity Regulator Type TGHE10-TGHE20-TGHE40
- Flare/solder Adaptor Type FSA
- Liquid Distributor Type RD21-RD26-RD27-RD33-RD42-RD49-RD62-RD79-RD85



Covered by this declaration is in conformity with the following directive(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

**Pressure Equipment Directive 2014/68/EU**

Types	DN (mm)	PS (bar)	Fluid Group	PED category	Standard	Additional standard
TD1/TDE1	6~12	34	2 <sup>(1)</sup>	Article 4, Paragraph 3	PED 2014/68/EU EN ISO 21922-2021 <sup>(3)</sup>	N/A
TD1/TDE1	6~12	34	1 <sup>(2)</sup>			
RD	12-28	49	2			
TGE/TGHE	6~32	49	2			
TGE/TGHE	6~25	49	1			CAS85535-84-8 <sup>(4)</sup>
TE5-55	12~25	28	1			
TE5-55	12~32	28	2			
FSA	6~18	46	1 & 2			

**Note:**

1. Fluid group 2 (non-toxic and non-flammable refrigerants);
2. Fluid group 1 (flammable or toxic refrigerants);

Date: 2023.04.19 Place of issue: 301700 Tianjin China	Issued by  <b>Signature:</b> <b>Name: Zhang Wei</b> <b>Title: Design Engineer</b>	Date: 2023.04.19 Place of issue: 301700 Tianjin China	Approved by  <b>Signature:</b> <b>Name: Jing (Amy) Xiao</b> <b>Title: Director of RD&amp;E , RAC-RPC</b>
---	--	---	---

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation

- 
- Solder connection is approved for the qualified A2L, A2, A3 refrigerants, see datasheet
  - Flare/MIO/ORFS connections are only approved for the qualified A2L refrigerants, see datasheet
3. EN ISO 21922-2021 "Refrigerating systems and heat pumps – Valves – Requirements, Testing and marking";
  4. Regulation of Kingdom of Norway, FOR-2004-06-01-922 "Product Control Regulation", §2-4. Short-chained chlorinated paraffin's.

**Ignition Hazard Assessments for component(s) used in fluid group I were conducted in accordance to :**

EN ISO 80079-36 Non-electrical equipment for explosive atmospheres – Basic method and requirements

The component(s) do not have its own source of ignition according to 2014/34/EU, Article 2 when operated as intended in normal conditions (Category3, Zone 2)

Equipment used for the above condition must be designed, installed and maintained according to: IEC60335-2-24/IEC60335-2-40/IEC60335-2-89/ EN378/ ISO5149/ GBT9237 or equivalent standards.